



## II. METHODS AND MATERIAL

The IEEE 14 bus system has two generators with three synchronous compensators which can be over excited synchronous machines. All the 14 buses have load points connected with active and reactive power consumption. Assuming that these loads are linear balanced loads the supply is provided with a single source at bus 1, by a tapping from the main power grid. The supply capacity of the power grid is limited to a certain value with complete power divided to all the buses. The complete load and generator data [6] of the 14 bus system can be seen below in table I.

TABLE I

| LOAD FLOW REPORT |      |         |         |       |            |         |        |        |           |      |          |         |         |        |        |
|------------------|------|---------|---------|-------|------------|---------|--------|--------|-----------|------|----------|---------|---------|--------|--------|
| Bus              |      | Voltage |         |       | Generation |         | Load   |        | Load Flow |      |          |         | XFMR    |        |        |
| ID               |      | kV      | Mag.    | ang.  | MW         | MVar    | MW     | MVar   | ID        | MW   | MVar     | Amp     | % PF    | % Tap  |        |
| * Bus 1          | H_1  | 1.000   | 106.000 | 0.0   | 232.404    | -16.561 | 0      | 0      | Bus 2     | H_2  | 156.888  | -20.405 | 86171.8 | 99.2   |        |
|                  |      |         |         |       |            |         |        |        | Bus 3     | H_3  | 73.237   | 3.260   | 40310.5 | 99.9   |        |
|                  |      |         |         |       |            |         |        |        | Bus 4     | H_4  | 56.133   | -1.262  | 31022.0 | -100.0 |        |
| * Bus 2          | H_2  | 1.000   | 104.200 | -0.0  | 40.000     | 43.333  | 21.700 | 12.700 | Bus 1     | H_1  | -122.290 | 27.678  | 82679.7 | -98.4  |        |
|                  |      |         |         |       |            |         |        |        | Bus 2     | H_2  | 73.237   | 3.260   | 40310.5 | 99.9   |        |
|                  |      |         |         |       |            |         |        |        | Bus 3     | H_3  | 73.237   | 3.260   | 40310.5 | 99.9   |        |
|                  |      |         |         |       |            |         |        |        | Bus 4     | H_4  | 56.133   | -1.262  | 31022.0 | -100.0 |        |
| * Bus 3          | H_3  | 1.000   | 101.000 | -12.7 | 0.000      | 23.063  | 94.200 | 19.000 | Bus 2     | H_2  | -70.914  | 1.602   | 40347.2 | -100.0 |        |
|                  |      |         |         |       |            |         |        |        | Bus 3     | H_3  | -23.236  | 4.461   | 13353.1 | -93.2  |        |
|                  |      |         |         |       |            |         |        |        | Bus 4     | H_4  | -24.456  | 3.033   | 30041.3 | -99.8  |        |
| Bus 4            | H_4  | 1.000   | 101.760 | -10.3 | 0          | 0       | 47.800 | -3.900 | Bus 2     | H_2  | 23.659   | -8.324  | 13694.4 | -93.0  |        |
|                  |      |         |         |       |            |         |        |        | Bus 3     | H_3  | -41.133  | 15.816  | 33332.7 | -96.8  |        |
|                  |      |         |         |       |            |         |        |        | Bus 7     | Z_7  | 28.071   | -0.639  | 16847.2 | -94.3  | -2.300 |
|                  |      |         |         |       |            |         |        |        | Bus 9     | L_9  | 16.081   | -0.433  | 9126.4  | -100.0 | -3.100 |
| Bus 5            | H_5  | 1.000   | 101.024 | -8.8  | 0          | 0       | 7.600  | 1.600  | Bus 1     | H_1  | -72.783  | 3.241   | 41218.3 | -100.0 |        |
|                  |      |         |         |       |            |         |        |        | Bus 2     | H_2  | -40.613  | -2.082  | 23030.2 | 99.9   |        |
|                  |      |         |         |       |            |         |        |        | Bus 4     | H_4  | 61.670   | -14.194 | 33332.7 | -97.2  |        |
|                  |      |         |         |       |            |         |        |        | Bus 6     | L_6  | 44.000   | 12.437  | 22046.6 | 96.2   | -8.900 |
| * Bus 6          | L_6  | 1.000   | 107.000 | -14.2 | 0.000      | 12.770  | 11.200 | 7.500  | Bus 1     | L_11 | 7.587    | 3.264   | 4431.1  | 99.0   |        |
|                  |      |         |         |       |            |         |        |        | Bus 12    | L_12 | 17.720   | 7.218   | 10399.3 | 92.2   |        |
|                  |      |         |         |       |            |         |        |        | Bus 13    | L_13 | -44.004  | -8.016  | 24182.2 | 98.4   |        |
| Bus 7            | Z_7  | 1.000   | 106.100 | -13.4 | 0          | 0       | 0      | 0      | Bus 5     | H_5  | 8.000    | -17.174 | 9241.1  | 9.0    |        |
|                  |      |         |         |       |            |         |        |        | Bus 9     | L_9  | 28.070   | 3.782   | 15857.6 | 97.9   |        |
|                  |      |         |         |       |            |         |        |        | Bus 4     | H_4  | -28.970  | 11.392  | 16476.6 | -92.7  |        |
| * Bus 8          | T_8  | 1.000   | 109.000 | -13.4 | 0.000      | 17.633  | 0      | 0      | Bus 7     | Z_7  | 8.000    | 17.693  | 9241.1  | 9.0    |        |
| Bus 9            | L_9  | 1.000   | 105.391 | -4.9  | 0          | 0       | 29.302 | -3.514 | Bus 7     | Z_7  | -28.970  | -4.900  | 15857.6 | 98.2   |        |
|                  |      |         |         |       |            |         |        |        | Bus 10    | L_10 | 5.224    | 4.216   | 2678.3  | 77.8   |        |
|                  |      |         |         |       |            |         |        |        | Bus 14    | L_14 | 9.424    | 3.605   | 2517.4  | 93.4   |        |
|                  |      |         |         |       |            |         |        |        | Bus 4     | H_4  | -16.000  | 1.740   | 2843.5  | 99.4   |        |
| Bus 10           | L_10 | 1.000   | 105.096 | -5.1  | 0          | 0       | 9.000  | 2.800  | Bus 9     | L_9  | -2.211   | -1.022  | 3470.3  | 78.0   |        |
|                  |      |         |         |       |            |         |        |        | Bus 11    | L_11 | -2.750   | -1.612  | 2262.5  | 92.0   |        |
| Bus 11           | L_11 | 1.000   | 105.690 | -4.8  | 0          | 0       | 3.500  | 1.800  | Bus 6     | L_6  | -3.202   | -3.443  | 4413.1  | 90.4   |        |
|                  |      |         |         |       |            |         |        |        | Bus 10    | L_10 | 3.802    | 1.643   | 2262.5  | 91.8   |        |
| Bus 12           | L_12 | 1.000   | 105.210 | -5.1  | 0          | 0       | 6.100  | 1.600  | Bus 6     | L_6  | -7.715   | -2.324  | 4413.4  | 92.6   |        |
|                  |      |         |         |       |            |         |        |        | Bus 13    | L_13 | 1.615    | 0.754   | 975.2   | 90.6   |        |
| Bus 13           | L_13 | 1.000   | 105.038 | -5.2  |            |         | 13.500 | 2.800  | Bus 6     | L_6  | -17.238  | -8.001  | 10399.3 |        |        |

The branch connection data from each bus to another is given below in TABLE II with its resistance, Reactance and Impedance of the line from bus to bus.

TABLE II

| Branch Connections |           |                  |        |        |      |                                      |       |       |           |
|--------------------|-----------|------------------|--------|--------|------|--------------------------------------|-------|-------|-----------|
| CKT/Branch         |           | Connected Bus ID |        |        |      | % Impedance, Pos. Seq., 100 MVA Base |       |       |           |
| ID                 | Type      | From Bus         | To Bus | R      | X    | Z                                    | Y     |       |           |
| 4_7                | 2W XFMR   | Bus 4            | H_4    | Bus 7  | Z_7  | 0.02                                 | 20.45 | 20.45 |           |
| 4_9                | 2W XFMR   | Bus 4            | H_4    | Bus 9  | L_9  | 0.05                                 | 53.89 | 53.89 |           |
| 5_6                | 2W XFMR   | Bus 5            | H_5    | Bus 6  | L_6  | 0.02                                 | 23.49 | 23.49 |           |
| 1_2                | Impedance | Bus 1            | H_1    | Bus 2  | H_2  | 1.94                                 | 5.92  | 6.23  | 5.2800000 |
| 1_5                | Impedance | Bus 1            | H_1    | Bus 5  | H_5  | 5.40                                 | 22.30 | 22.95 | 4.9200000 |
| 2_3                | Impedance | Bus 2            | H_2    | Bus 3  | H_3  | 4.70                                 | 19.80 | 20.35 | 4.3800000 |
| 2_4                | Impedance | Bus 2            | H_2    | Bus 4  | H_4  | 5.81                                 | 17.63 | 18.56 | 3.4000000 |
| 2_5                | Impedance | Bus 2            | H_2    | Bus 5  | H_5  | 5.70                                 | 17.39 | 18.30 | 3.4000000 |
| 3_4                | Impedance | Bus 3            | H_3    | Bus 4  | H_4  | 6.70                                 | 17.10 | 18.37 | 1.2800000 |
| 4_5                | Impedance | Bus 4            | H_4    | Bus 5  | H_5  | 1.34                                 | 4.21  | 4.42  |           |
| 6_11               | Impedance | Bus 6            | L_6    | Bus 11 | L_11 | 9.50                                 | 19.89 | 22.04 |           |
| 6_12               | Impedance | Bus 6            | L_6    | Bus 12 | L_12 | 12.20                                | 25.58 | 28.38 |           |
| 6_13               | Impedance | Bus 6            | L_6    | Bus 13 | L_13 | 6.62                                 | 13.03 | 14.61 |           |
| 7_8                | Impedance | Bus 7            | Z_7    | Bus 8  | T_8  | 17.62                                | 17.62 |       |           |
| 7_9                | Impedance | Bus 7            | Z_7    | Bus 9  | L_9  | 11.00                                | 11.00 |       |           |
| 9_10               | Impedance | Bus 9            | L_9    | Bus 10 | L_10 | 3.18                                 | 8.45  | 9.03  |           |
| 9_14               | Impedance | Bus 9            | L_9    | Bus 14 | L_14 | 12.71                                | 27.04 | 29.88 |           |
| 10_11              | Impedance | Bus 10           | L_10   | Bus 11 | L_11 | 8.21                                 | 19.21 | 20.89 |           |
| 12_13              | Impedance | Bus 12           | L_12   | Bus 13 | L_13 | 22.06                                | 19.99 | 29.79 |           |
| 13_14              | Impedance | Bus 13           | L_13   | Bus 14 | L_14 | 17.06                                | 34.80 | 38.77 |           |

To the above IEEE 14 bus system a STATCOM is connected at the weak bus which is denoted by the load flow solution using newton raphson method. The weak load bus is considered to be 14<sup>th</sup> bus which has the lowest voltage pu value and the voltage pu values of all the buses are shown in the fig.2 below.




Figure 2. pu Voltages of IEEE 14bus system without STATCOM

## III. RESULTS AND DISCUSSION

The figure with IEEE 14 bus system with STATCOM connected at the 14<sup>th</sup> bus is shown modeled in MATLAB Simulink is shown below.





Figure 3. MATLAB Simulink modeling of IEEE 14 bus system with STATCOM at 14<sup>th</sup> bus


The After connection of STATCOM at the 14<sup>th</sup> bus the voltage pu of the 14 bus system is improvised as a result of injection of reactive power from STATCOM stabilizing the buses connected nearer to the

STATCOM device. The voltage pu values of the 14 bus system are shown below in fig.4



**Figure 4.** pu Voltages of IEEE 14bus system with STATCOM at 14<sup>th</sup> bus

It can be cleared that the voltage at 14<sup>th</sup> bus is improvised to 0.982 from 0.9387 representing without STATCOM and with STATCOM the bus voltages are now in the permissible range i.e., between 0.95 to 1.05. A graphical representation of bus voltage comparison can be seen in the fig.5 below.



**Figure 5.** Comparison of voltages for IEEE 14 bus system with and without STATCOM

#### IV.CONCLUSION

With the above representation and comparison of graphs with the help of MATLAB software it can be observed that the voltages of the buses have been improved and set to IEEE standard range (0.95 to 1.05) and stable with respect to no FACTs device in the 14 bus IEEE distribution bus system. All the analysis and modeling with graphical representations of the bus system with STATCOM at bus 14 are carried out in MATLAB Simulink software with genuine results

#### V. REFERENCES

- [1]. IEEE Standards Board (1995), "IEEE Std. 1159-1995" IEEE recommended practice for monitoring electric power quality, IEEE Inc. NewYork.
- [2]. Bollen. M, "Understanding power quality problems: Voltage sags and interruptions," Piscataway, NJ, IEEE Press, 2nd edition 2000.
- [3]. Pirjo Heine and Matti Lehtonen, "Voltage sag distributions caused by power system faults", IEEE Transactions on Power Systems, Vol. 18, No.4, pp. 1367-1373, November 2003.
- [4]. Soo-Young Jung, Tae-Hyun Kim, Seung-II Moon and Byung-Moon Han, "Analysis and control of DSTATCOM for a line voltage Regulation", Power Engineering Society Winter Meeting 2002, Vol. 2, pp. 726-734, January 27-31, 2002.
- [5]. N. G. Hingorani and L. Gyugyi, "Understanding FACTS: Concepts and technology of Flexible AC Transmission System", IEEE publication, 2000.
- [6]. J. Dixon, Luis Moran, Jose Rodriguez, "Reactive power compensation technologies: State of art review", Proceedings of the IEEE, Vol.93, No. 12, pp. 2144-2164, December 2005.
- [7]. A. Ghosh and G. Ledwich, "Power quality enhancement using custom power devices," Kluwer Academic Publisher, London, 2002.
- [8]. Arindam Ghosh and Gerard Ledwich, "Compensation of distribution system voltage using DVR", IEEE Transactions on Power Delivery, Vol. 17, No. 4, pp. 1030-1036, October 2002.
- [9]. D. Mahinda Vilathgamuwa, A.A.D. Ranjith Perera and S. S. Choi, "Voltage sag compensation with energy optimized Dynamic Voltage Restorer", IEEE Transactions on Power Delivery, Vol. 18, No. 3, pp. 928-936, July 2003.